

INSTALLATION INSTRUCTIONS



WMC-2C-50K-U WMC-3C-50K-U LED Wallpack Cube

SAFETY PRECAUTION:

- CAUTION: This product uses an input 120-277VAC wide range driver and photocell.
- WARNING: To avoid the risk of fire, explosion, or electric shock, this product should be installed, inspected, and maintained by a qualified electrician only, in accordance with all applicable electrical codes
- WARNING: To avoid electric shock be certain electrical power is OFF before and during installation and maintenance.
- WARNING: To avoid electric shock luminaire must be connected to a wiring system with an equipment-grounding conductor.
- WARNING: Make sure the supply voltage is the same as the rated luminaire voltage.
- WARNING: Do not operate in ambient temperatures above those indicated on the luminaire nameplate.

SUITABLE FOR USE IN WET LOCATIONS


FOR SUPPLY CONNECTIONS USE WIRE RATED FOR AT LEAST 90°C.


AMBIENT TEMP: -20-+40°C


INSTALLATION:


ALWAYS TURN OFF THE POWER SUPPLY FROM MAIN CIRCUIT BREAKER FIRST!


- 1. Remove the two screws on both sides of the lamp shade, then take off the lamp shade. (See Fig. 1)
- 2. Remove the two screws as shown in the picture, take off the driver box. (See Fig. 2)
- 3. Attach the fixture back plate to the junction box. (See Fig. 3)
- 4. Reattach the driver box. (See Fig. 4)
- 5. Install shade. (See Fig. 5)











EiKO Global, LLC • 23220 W. 84th St, Shawnee, KS 66227 • (P) 1-800-852-2217 • (F) 1-800-492-8975 • eiko.com EiKO Canada • 81 King St, Barrie, Ontario L4N 6B5 • (P) 1-705-721-5189 • (F) 1-705-721-7855 • orderdesk@eiko.com

INSTALLATION (cont.):

WIRING DIAGRAMS

